

Report Number	Residence Hall	Location Detail	Date/Time Occurred	Nature
090165	Letts Hall	5th Floor Kitchen	3/2/2009 23:31	NCC Alarm received, officer responded determined that there was a slight smell of smoke coming from the stove. Negative for signs of fire.
090345	Anderson Hall	North Stairwell	4/26/2009 23:10	NCC Alarm received. Officers responded and slight smoke smell and no signs of fire
090397	Leonard Hall	4th Floor Kitchen	5/8/2009 1:43	Property was set on fire and thrown from a residence hall window
090413	Anderson Hall	Boiler Room	5/19/2009 13:12	Contractors working in the Boiler Room set off the alarm
090424	Capital Hall	4th Floor Hallway	5/28/2009 21:17	A fire alarm was activated due to a cooking error. No Fire was present
090430	Capital Hall	Kitchen	6/3/2009 16:26	A fire alarm was activated due to a cooking error. No Fire was present, small amount of smoke
090436	Centennial Hall	Mechanical Room	6/9/2009 10:12	A fire alarm was activated due to contractors welding
090442	Capital Hall	Kitchen	6/11/2009 21:20	Fire Alarm caused by over-cooked food
090571	Hughes Hall	Front of Building	8/23/2009 17:29	Cigarette was thrown into a trashcan
090624	Federal Hall	Inside of resident room	9/12/2009 0:46	Contents of a personal trashcan accidentally set ablaze
090668	Capital Hall	Kitchen	9/19/2009 18:12	Cooking of food caused smoke
090673	Letts Hall	4th Floor Lounge	9/21/2009 18:25	Cooking of food caused system alarm
090703	Anderson Hall	Elevator	9/27/2009 2:56	Arson-Malicious Burning
090748	Anderson Hall	Front of Building	10/7/2009 22:42	Burning Mulch
090785	Letts Hall	4th Floor Lounge	10/16/2009 18:43	Buring Food Caused Alarm
090832	Anderson Hall	6th floor microwave	10/26/2009 16:00	Overcooked food in microwave caused smoke